



Fire Behavior Statement

StrongTouch | 51.101N

Company	Fourbases BV, representing iSee2 products Groendreef 35, 9880 Aalter, Belgium
Description of samples	White polymer self-adhesive foil consisting of PVC in a nominal thickness of 90 μ
Name of material	StrongTouch 51.101N
Content of request	Proof of flammability to classify building materials to class B according to the procedures given in EN 13501-1:2018
Test methods	EN ISO 11925-2 EN 13823
Result	This product is classified in relation to its reaction to fire behaviour: class B. The additional classification in relation to smoke production is: s2. The additional classification in relation to flaming droplets/particles is: d0. Reaction to fire classification: B - s2, d0

For more information, please contact us via info@fourbases.eu.

