



Fire Behavior Statement

Silver Etch 7Y | 51.121N

Company	Fourbases BV, representing iSee2 products Groendreef 35, 9880 Aalter, Belgium
Description of samples	Translucent polymeric self-adhesive foil consisting of PVC bonded to a paper face plasterboard substrate in a nominal thickness of 95 micron
Name of material	Silver Etch 7Y 51.121N
Sampling	By iSee2
Content of request	Proof of flammability to classify building materials to class B1 according to the procedures given in EN 13501-1:2007.
Test methods	EN ISO 11925-2 EN 13823 EN/TS 15117
Result	The examined product is classified in relation to its reaction to fire behaviour: class B. The additional classification in relation to smoke production is: s2. The additional classification in relation to flaming droplets/particles is: d0. Reaction to fire classification: B - s2, d0
Field of application	The product is defined as being suitable for construction applications, excluding flooring and linear pipe thermal insulation. The classification is valid for wall or ceiling applications used over any substrate with a density equal to or greater than 800 kg/m ³ , having a minimum thickness of 12mm and a fire performance of A2FL or better.

For more information, please contact us via info@fourbases.eu.

